

### SMOKE AND CARBON MONOXIDE ALARMS AFFIDAVIT

#### DECLARATION OF INSTALLATION IN RESIDENTIAL OCCUPANCIES

FOR COMPLIANCE WITH THE 2019 CALIFORNIA BUILDING CODE (CBC) AND 2019 CALIFORNIA RESIDENTIAL CODE (CRC) WHERE NO INTERIOR ACCESS IS REQUIRED FOR INSPECTION.

PERMIT #: 21113  
 PROPERTY ADDRESS: 1918 MCKINLEY AVE, 1920 McKinley  
 PROPERTY OWNER'S NAME: DRUM, ALFRED D  
 NUMBER OF ALARMS INSTALLED: SMOKE: 2 CARBON MONOXIDE: 1

When any alterations, repairs or additions requiring a permit occur, or sleeping rooms are created, smoke/carbon monoxide\* alarms shall be installed in the following locations(sections CBC 907.2.10.2, CRC R314.2 and CRC R315.2):

Room/Space	Smoke Alarm Required? (CBC 907.2.10.2 and CRC R314.2)	Carbon Monoxide Alarm Required? (CRC R315.2)
In each sleeping room	Yes	No
Outside of each separate sleeping area in the immediate vicinity of bedrooms (i.e. hallway)	Yes	Yes
In each sleeping room with fuel burning appliance	Yes	Yes
In each story within a dwelling unit, including basements	Yes	Yes

\* Carbon Monoxide alarms are not required in dwellings that do not contain fuel-burning appliances and that do not have an attached garage.

**Multi-Purpose Alarms:** Carbon Monoxide alarms combined with smoke alarms shall comply with Section R314.5 and R315.4 of the California Residential Code and shall be approved by the Office of the State Fire Marshall.

**Power Supply:** In dwelling units with no commercial power supply, alarm(s) may be solely battery operated. In existing dwelling units, alarms are permitted to be solely battery operated where repairs or alterations do not result in the removal of wall and ceiling finishes or there is no access by means of attic, basement, or crawl space. See sections CBC907.2.11.9, CRC 314 and CRC 315 of the California Building and California Residential Codes. An electrical permit is required for alarms which must be connected to the building wiring.

As owner/contractor of the above-referenced property, I/We affirm and declare that the alarms referenced above have been installed in accordance with the manufacture's instructions and in compliance with the California Building and California Residential Codes. The alarms have been tested and are operational.

The property owner and contractor shall sign the affidavit for document to be accepted:

\* Print Owner's Name: Alfred Drum Date: 4-23-2021  
 Owner's Signature: alfred Drum Date: 4-23-2021  
 Print Contractor's Name: Rollie Waldow Date: 4-23-21  
 Contractor's Signature: Rollie Waldow Date: 4-23-21

See Back of Page for Placement Diagram